



# PQ Dashboard Updates at TVA

---

Tony Murphy

April 25, 2018

# Multiple Fault Locations

## Fault Location Reports

**Fault Inception Time:** 2018-03-10 23:15:26.7511875

**Fault Duration:** 5.49 cycles / 91.13 ms

**Fault Type:** CA


**Location:** 9.66 miles from [redacted] on [redacted] 161kV Line (L5855)

**Tree Probability:** Undetermined


**View:** [Miles](#) [TeleGyr](#) [Quick BSL Search](#)

2 structures found matching distance criteria

**Solution 1 Nearest Structure:** 616 @ (3[redacted], 3[redacted])



**Solution 2 Nearest Structure:** 628 @ (3[redacted], 3[redacted])





# SOE Alarm Integration

## Fault Location Reports

**Fault Inception Time:** 2018-03-10 23:15:26.7511875

**Fault Duration:** 5.49 cycles / 91.13 ms

**Fault Type:** CA

**Location:** 9.66 miles from  (S) on ville 161kV Line (L)

SOE

Time Window (s): 2 Filter (remove selected): ☐ ABNORMAL ☐ Failure ☐ NORMAL ☐ RECEIVED ☐ Run ☐ Start ☐ Stop ☐ Trip

Refresh

Time	Alarm	Status
3/10/2018 11:15:27 PM	PCB 944 SS RELAY FAILURE	ABNORMAL
3/10/2018 11:15:27 PM	PCB 1014 LOSS OF AC VOLTAGE	ABNORMAL
3/10/2018 11:15:27 PM	PCB 1024 LOSS OF AC VOLTAGE	ABNORMAL
3/10/2018 11:15:27 PM	DFR RUNNING	Run
3/10/2018 11:15:27 PM	PCB 944 SS RELAY FAILURE	NORMAL
3/10/2018 11:15:27 PM	DFR RUNNING	Stop
3/10/2018 11:15:27 PM	PCB 1014 LOSS OF AC VOLTAGE	NORMAL

SOE

Time Window (s): 60 Filter (remove selected): ☒ ABNORMAL ☐ Close ☒ Failure ☒ NORMAL ☒ RECEIVED ☒ Run ☒ Start ☒ Stop ☐ Trip

Refresh

Time	Alarm	Status
3/10/2018 11:15:22 PM	PCB 924	Trip
3/10/2018 11:15:24 PM	PCB 924	Close
3/10/2018 11:15:27 PM	PCB 918 SS B2	Trip
3/10/2018 11:15:27 PM	PCB 914 SS B1	Trip
3/10/2018 11:15:31 PM	PCB 918 SS B2	Close
3/10/2018 11:15:31 PM	PCB 914 SS B1	Close

# SIDA & PQWeb Correlation

## Fault Location Reports

**Fault Inception Time:** 2018-03-19 18:43:44.5940972

**Fault Duration:** 4.48 cycles / 74.35 ms

**Fault Type:** AN

**Location:** 2.12 miles from  (S) on  161kV Line (L)

**Tree Probability:** Medium (Rf=10.96 )

**View:** [Miles](#) [TeleGyr](#) [Quick BSL Search](#)

Corresponding  
SIDA Reports

SIDA Event Number	Event Time	Equipment Name	kV	Duration (HH:MM)	OM Office	Cause	Subcause
<a href="#">456733</a>	2018-03-19 18:43:44.0000000		161	0:0	MURF	TORNADO	DEBRIS

PQWEB  
Reports

PQWeb® 3.2.2

Event List

[Reports](#) [Event Preferences](#) [Graph Preferences](#) [Help](#)

From 3/19/2018 6:42:44 PM to 3/19/2018 6:44:44 PM


Site Name	Time Stamp	Event Type	Voltage Magnitude
 161-T1-T2 ION	<a href="#">03-19-2018 18:43:44.595</a>	RMS Variation	78.02%

Table includes 1 events.

# Faults Other Than Line Faults

- Capacitor Banks
- Transformer Banks
- Generators
- Busses
- Customer Loads

Line #:	S5A93S
Name:	161/23kV Transformer Bank 1
kV:	161
Thermal Rating:	947
Length:	0.05
R0:	1.02647
X0:	22.01557
R1:	1.02647
X1:	25.90067

# Probability of Tree Faults

## Fault Location Reports

Fault Inception Time: 2011-10-16 18:19:24.2538194

Fault Duration: 14.34 cycles / 238.11 ms


Fault Type: CN

Location: 3.66 miles from [REDACTED] TN (S[REDACTED]) on [REDACTED] Road 161kV Line (L[REDACTED])


Tree Probability: Medium (Rf=19.84)

View: [Miles](#) [TeleGyr](#) [Quick BSL Search](#)

## Fault Imp. Vector




## Fault Distance



Loop Imp (LG)			
ZS (Ohm)	Ang (Deg)	RS (Ohm)	XS (Ohm)
18.022	77.664	3.8510	17.6055
1.395	-	0.2981	1.3627

## Tree Fault Probability



# Fault Notification: Custom Email Templates

## Customer Account Manager Email:

Subject: Fault detected on Paradise FP-Hopkinsville 161kV Line 1 (L5619)

### Fault 1

Faulted Line:	161kV Line 1 (L5619)
Fault Type:	B-phase to C-phase
Fault Time:	2017-11-19 13:26:15 (CT)
Fault Clearing:	1.4cyc a
Tree probability:	Undetermined
Click for fault reports:	<a href="#">1066662</a>

### Disturbance 1


#### Customers and equipment affected:

Customer	Area	Section	Component Model	Manufacturer	Series	Component Type	Magnitude (pu)	Duration (s)
	Standard	1668	12C-10	ABB	General Purpose	Ice Cube Relay	0	0.009

## Linemen SMS Text Message:










(Fault Detected) 161kV Line 4 (L5619) @ 2018-04-16 03:32:53CT,  
Type AN @ S372 Tree = Low

# Completeness and Correctness Use Case





# Completeness and Correctness Use Case


Correctness Detail for 1 for 9/24/2017										
Channel Name	Type	Characteristic	Phase	Expected	Good	Latched	Unreasonable	Noncongruent	Duplicate	
V RMS A	Voltage	RMS	AN	144	114	0	0	0	0	0 
V RMS B	Voltage	RMS	BN	144	113	1	0	0	0	0 
V RMS C	Voltage	RMS	CN	144	114	0	0	0	0	0 
V THD A	Voltage	TotalTHD	AN	144	114	0	0	0	0	0 
V THD B	Voltage	TotalTHD	BN	144	114	0	0	0	0	0 
V THD C	Voltage	TotalTHD	CN	144	114	0	0	0	0	0 
I RMS A	Current	RMS	AN	144	114	0	0	0	0	0 
I RMS B	Current	RMS	BN	144	114	0	0	0	0	0 
I RMS C	Current	RMS	CN	144	114	0	0	0	0	0 

# Completeness and Correctness Use Case



## openSTE • Trending Data Viewer

-- Voltage - RMS - BN - 9/24/2017 12:00:00 AM for a Day



# Looking Ahead

- Fault Location Accuracy Improvements
  - Include Mutual Impedances
  - Adjust Cycle in Fault for Location Calculations
- Integrating SCADA Points from Dataware/eDNA
- Improve Fault Suppression Logic
- DFR Timestamp Correction
- Email Subscription / Management
- Addition of Other Element Types (Capacitors, etc)
- New CSA DLL and OpenEAS
- Predict Other Fault Causes (Smoke, Arrester, etc)

# Questions?



