

PQDashboard User's Group

openXDA Improvements

Probable Fault Cause
Integration with SCADA

Stephen Wills

May 9, 2019

The Candidate Initial Fault Cause Analytics

- Lightning – No waveform analytics. Cause based on time correlation with lightning strike data (Vaisala)
- Conductor Break
- Tree-In-Line
- Conductor Slap / Debris Mid-Line
- Lightning Arrestor Failure
- Insulator Breakdown due to Contamination


Cause: Lightning

■ Approach

- Query lightning database for lightning strikes in close proximity of faulted line and close time proximity of event

■ Observations

- Only works with access to a lightning database and GIS line data
- Only tested one case
- Did not test for false positives




Cause: Conductor Break

■ Approach

- For phase-to-ground faults, check if prefault current disappears in exactly one phase

■ Observations

- 3 out of 5 test cases correctly categorized
- 2 out of 5 test cases from phase-to-phase conductor break event; prefault current disappears in C-phase, but this violates the phase-to-ground assumption
- No false positives



Cause: Tree-in-Line

■ Approach

- For phase-to-ground faults, check for high fault resistance of tree

$$R_F = \sqrt{(X_S D_S)^2 - (X_S D_R)^2} - R_S D_R$$

where:

R_F = Fault Resistance of Tree (Ω)

R_S = Line Loop Resistance (Ω /mile)

X_S = Line Loop Reactance (Ω /mile)

D_S = Calculated Fault Location using Simple Method (miles)

D_R = Calculated Fault Location using Reactance Method (miles)

■ Observations

- 9 out of 9 cases correctly categorized
- 1 false positive
- Frequently conflicts with lightning arrester failure and insulation contamination



Cause: Conductor Slap / Debris Midline

■ Approach

- For phase-to-phase faults, check for the absence of ground current during the fault

■ Observations

- 6 out of 6 cases of debris correctly categorized
- 1 false positive
- Seems accurate, but test library did not contain very many phase-to-phase faults
- Very little overlap with other fault cause categories (L-L vs L-N)



Cause: Lightning Arrestor Failure

■ Approach

- For phase-to-ground faults with prefault load current, check for significant magnitude in third harmonic on current waveform of faulted phase

■ Observations

- 3 out of 5 test cases correctly categorized
- 1 false positive
- Third harmonic signature does not always appear
- Accurate fault inception is necessary for this analysis
 - Surge is typically only visible within one cycle of fault inception
 - At point of fault inception, all harmonics spike during wave shape transition



Cause: Insulator Breakdown due to Contamination

■ Approach


- For phase-to-ground faults, check if fault inception is close in proximity to the peak of the voltage waveform

■ Observations

- 4 out of 5 test cases correctly categorized
- 5 false positives
- Accurate fault inception is necessary for this analysis
- Seems to be prone to false positives



Summary – Determining Likely Cause



Decreasing
Analytic
Certainty

Cause	Prob. Levels	High Probability
Break	High, Low	Must have pre-fault current and be a L-G fault. High if pre-fault current goes to zero in faulted phase
Lightning	High, Med, Low	Lightning occurs within 2 mSec of fault inception
Tree	High, Med, Low	Must be a L-G fault. "Fault resistance" is ≥ 20 ohms
Slap/Debris	High, Low	Must be a L-L fault. Ratio of ground current to fault current < 0.3
Arrestor	High, Low	Must have pre-fault current and be a L-G fault. Ratio of third harmonic to first harmonic for pre-fault current $> 10\%$
Insulator	High, Med, Low	Must have pre-fault current and be a L-G fault. Phase shift pre-fault to fault-inception ± 15 degrees.


Likely cause = only one 'high probability' found → display cause

= multiple 'high probability' found → display cause with most certainty and "?"

= no 'high' and one or more 'medium' found → display cause with most certainty and "??"

ELSE display cause as "unknown"

Interesting Summary Data: Unknown Cause



- Actual cause reported was conductor break
- Start of waveform indicates conditions for conductor break with no current on C-phase
- Anomaly on B-phase occurs
 - Fault analysis classifies as AB
- Load current disappears (did the breaker open?)
- New fault occurs several cycles later
 - Fault analysis classifies as BC

Interesting Summary Data: False Positive Cause



- Actual cause: insulation contamination
- Inception was wrong because the fault occurred as the sine wave was decaying so the total fault amplitude could not be observed until the next half-cycle
- Using the correct fault inception, fault would be classified as Unknown

Next Steps To Improve Fault Cause Determination

- Refine and test current analytics with multiple more test cases.
 - Tune parameters
- Improve algorithm for fault inception determination
- Add binary signature attributes to fault results to add insight into cause and/or be part of future cause determination analytics
 - Arcing?
 - Bolted?
 - High Resistance?
 - CT saturation?
 - Waveform clipping?
 - Ferro-resonance?
- Add more cause analytics (“smoke” coming soon)

Integration with SCADA – openXDA Version 2.4

■ Problem Statement

- Need to reduce false positive faults detected by openXDA

■ Solution

- Integrate with SCADA data to validate breaker operation

